

# FLAMMABLE & COMBUSTIBLE MATERIALS

HAZARD	Satisfactory	Needs Attention	Target Date of Correction	Date Corrected
Are combustible scrap, debris and waste materials (oily rags, etc.) stored in covered metal receptacles and removed from the work site promptly?				
Is proper storage practiced to minimize the risk of fire including spontaneous combustion?				
Are approved containers and tanks used for the storage and handling of flammable and combustible liquids?				
Are all connections on drums and combustible liquid piping, vapor and liquid tight?				
Are all flammable liquids kept in closed containers when not in use (e.g., parts cleaning tanks, pans, etc.)?				
Are bulk drums of flammable liquids grounded and bonded to containers during dispensing?				
Do storage rooms for flammable and combustible liquids have explosion-proof lights?				
Do storage rooms for flammable and combustible liquids have mechanical or gravity ventilation?				
Is liquefied petroleum gas stored, handled, and used in accordance with safe practices and standards?				
Are <b>NO SMOKING</b> signs posted on liquefied petroleum gas tanks?				
Are liquefied petroleum storage tanks guarded to prevent damage from vehicles?				
Are all solvent wastes, and flammable liquids kept in fire-resistant, covered containers until they are removed from the work site?				

_____	_____
Name	Date

-over-

# FLAMMABLE & COMBUSTIBLE MATERIALS

<b>HAZARD</b>	<b>Satisfactory</b>	<b>Needs Attention</b>	<b>Target Date of Correction</b>	<b>Date Corrected</b>
Is vacuuming used whenever possible rather than blowing or sweeping combustible dust?				
Are fire separators placed between containers of combustibles or flammables, when stacked one upon another, to assure their support and stability?				
Are fire extinguishers selected and provided for the types of materials in areas where they are to be used?  Class A-Ordinary combustible material fires. Class B - Flammable liquid, gas or grease fires. Class C - Energized-electrical equipment fires.				
Are appropriate fire extinguishers mounted within 75 ft of outside areas containing flammable liquids and within 10 ft of any inside storage area for such materials?				
Are all extinguishers serviced, maintained and tagged at intervals not to exceed one year?				
Are extinguishers free from obstructions or blockage?				
Are all extinguishers fully charged and in their designated places?				
Where sprinkler systems are permanently installed, are the nozzle heads so directed or arranged that water will not be sprayed into operating electrical switch boards and equipment?				
Are " <b>NO SMOKING</b> " signs posted where appropriate in areas where flammable or combustible materials are used or stored?				
Are safety cans used for dispensing flammable or combustible liquids at a point use?				
<div style="display: flex; justify-content: space-between; margin: 0;"> <div style="width: 60%; border-top: 1px solid black; text-align: center;">Name</div> <div style="width: 35%; border-top: 1px solid black; text-align: center;">Date</div> </div>				

# FLAMMABLE & COMBUSTIBLE MATERIALS

<b>HAZARD</b>	<b>Satisfactory</b>	<b>Needs Attention</b>	<b>Target Date of Correction</b>	<b>Date Corrected</b>
Are all spills of flammable or combustible liquids cleaned up promptly?				
Are storage tanks adequately vented to prevent the development of excessive vacuum or pressure as a result of filling, emptying, or atmosphere temperature changes?				
Are storage tanks equipped with emergency venting that will relieve excessive internal pressure caused by fire exposure?				
Are " <b>NO SMOKING</b> " rules enforced in areas involving storage and use of hazardous materials?				
If a Halon 1301 fire extinguisher is used, can employees evacuate within the specified time for that extinguisher?				
Is the transfer/withdrawal of flammable or combustible liquids performed by trained personnel?				
Are employees trained in the use of fire extinguishers?				

_____	_____
Name	Date