

SPRAYING OPERATIONS

| HAZARD | Satisfactory | Needs Attention | Target Date For Completion | Date Corrected |
|--|--------------|-----------------|----------------------------|----------------|
| Is adequate ventilation assured before spray operations are started? | | | | |
| Is mechanical ventilation provided when spraying operation is done in enclosed areas? | | | | |
| When mechanical ventilation is provided during spraying operations, is it so arranged that it will not circulate the contaminated air? | | | | |
| Is the spray area free of hot surfaces? | | | | |
| Is the spray area at least 20 feet from flames, sparks, operating electrical motors and other ignition sources? | | | | |
| Are portable lamps used to illuminate spray areas suitable for use in hazardous location? | | | | |
| Is suitable respiratory equipment provided and used when appropriate during spraying operations? | | | | |
| Do solvents used for cleaning have a flash point of 100 degrees Fahrenheit or more? | | | | |
| Are fire control sprinkler heads kept clean? | | | | |
| Are " NO SMOKING " signs posted in spray areas, paint rooms, paint booths, and paint storage areas? | | | | |
| Is the spray area kept clean of combustible residue? | | | | |
| <div style="display: flex; justify-content: space-between; margin-top: 20px;"> _____ _____ </div> <div style="display: flex; justify-content: space-between; margin-top: 5px;"> Name Date </div> | | | | |

SPRAYING OPERATIONS

| HAZARD | Satisfactory | Needs Attention | Target Date For Completion | Date Corrected |
|---|---------------------|------------------------|-----------------------------------|-----------------------|
| Are spray booth floors and baffles noncombustible and easily cleaned? | | | | |
| Is infrared drying apparatus kept out of the spray area during spraying operations? | | | | |
| Is the spray booth completely ventilated before using the drying apparatus? | | | | |
| Is the electric drying apparatus properly grounded? | | | | |
| Are lighting fixtures for spray booths located outside of the booth and the interior lighted through sealed clear panels? | | | | |
| Are the electric motors for exhaust fans placed outside booths or ducts? | | | | |
| Are belts and pulleys inside the booth fully enclosed? | | | | |
| Do ducts have access doors to allow cleaning? | | | | |
| Do all drying spaces have adequate ventilation? | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |

Name

Date